



Certificate of Compliance

Certificate: 2193117 **Master Contract:** 169786 (LL 36040)

Project: 70112312 **Date Issued:** 2016-12-14

Issued to: Nexans Suisse SA
2 rue de la Fabrique
Cortailod, Neuchatel 2016
SWITZERLAND
Attention: John Peter Mattmann

The products listed below are eligible to bear the CSA Mark shown



Kim Nguyen
Issued by: Kim Nguyen, P. Eng.

PRODUCTS

CLASS 5851 01 - WIRES – Appliance

Appliance Wiring Material, single conductor construction with Silicone Rubber insulation, optional insulation shielding, optional overall shielding, and a synthetic yarn braid covering ¹, class I, group A/B, rated at 150C and 180C, 1100/3300/6900/10000V ac, -55C, FT2.

Note: ¹ May be replaced by a Silicone Rubber jacket.

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No. 210-15 - Appliance Wiring Material Products



Supplement to Certificate of Compliance

Certificate: 2193117

Master Contract: 169786 (LL 36040)

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70112312	2016-12-14	Update to CSA C22.2 No. 210-15.
2193117	2009-12-17	Single conductor with Silicone Rubber insulation, optional insulation shielding, optional overall shielding, and a synthetic yarn braid covering , rated 150C, 180C, 1100/3300/6900/10000V AC, -55C, FT2.